

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-1496:134 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Firecom, Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Models FCH70-24 and FCH-90-24 chimes. All units may be followed by additional suffixes to designate lens orientation, lens lettering and plate color. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as chimes for use with separately listed compatible fire alarm control units. For private mode and indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLf: 7135-0785:109



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 22, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager